

SECTION 16525 - EXTERIOR LIGHTING

A. SUMMARY

1. Exterior lighting fixtures, lamps, ballasts, pole standards, and accessories.

B. WARRANTY

1. Fixture Finish: Five years.

C. PRODUCTS

1. Fluorescent Ballasts: Low-temperature, electromagnetic type; sound rating "A"; and minimum starting temperature of minus 20 deg C.
2. HID Ballasts: Constant-wattage or regulating high-power-factor type, with one fuse for each supply conductor.
 - a. High-Pressure Sodium Ballast: Solid-state igniter/starter.
 - b. Minimum Starting Temperature: Minus 30 deg C.
 - c. Sound Rating: "B" or better.
3. Instant restrike device for HPS lamps.
4. Auxiliary instant-on quartz lamp for HID lamps.

D. FIELD QUALITY CONTROL

1. Testing Agency: Contractor employed.

END OF SECTION 16525